



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14317-7-5653
State Number
17535

EQUIPMENT INSPECTED

State Number: 17535	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/08/1999	Rope Size:
Volts: 480	Complied: 06/08/1999	Entrances: 1

OWNER

ASHE COUNTY BOARD OF EDUCATION
PO BOX 604
JEFFERSON, NC, 28640

OCCUPANT

ASHE COUNTY HIGH SCHOOL
184 CAMPUS DR
WEST JEFFERSON, NC, 28694

INSPECTION INFORMATION

Inspection Date 11/13/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

8.11.3.2.1 PERFORM THE ANNUAL RELIEF VALVE TEST, LAST TEST 2-12

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ASHE CO.. 336-246-7175

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE COUNTY BOARD OF EDUCATION
PO BOX 604
JEFFERSON, NC, 28640