

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 14322-8-2780 State Number 1167

EQUIPMENT INSPECTED

State Number: 1167	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 75
Landings: 2	Installed: 10/11/1948	Rope Size: 1/2
Volts: 220	Complied: 10/11/1948	Entrances: 1
OWNER	OCCUPANT	
RANDOLPH CO SENIOR ADULTS ASSOC,INC	RANDOLPH CO SR ADULTS ASSOC,INC	
PO BOX 1852	149 NORTH CHURCH ST	
ASHEBORO, NC, 28204-1852	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 11/18/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH	76
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	----

VIOLATIONS

8.11.1.2 PERFORM 5YR FULL LOAD GOV & SAFTY TEST

Items must be corrected by: 12/18/2014

Elevator Name: Plant 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TOMMY SIMPSON 336.625.2161

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH CO SENIOR ADULTS ASSOC,INC
PO BOX 1852
ASHEBORO, NC, 28204-1852