



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14324-48-4494
State Number
20788

EQUIPMENT INSPECTED

State Number: 20788	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 04/22/2002	Rope Size:
Volts: 208	Complied: 04/24/2002	Entrances: 2
OWNER	OCCUPANT	
ELIZABETHTOWN BAPTIST CHURCH	ELIZABETHTOWN BAPTIST CHURCH	
1800 W BROAD ST	1800 W BROAD ST	
ELIZABETHTOWN, NC, 28337	ELIZABETHTOWN, NC, 28337	

INSPECTION INFORMATION

Inspection Date 11/20/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 12/20/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELIZABETHTOWN BAPTIST CHURCH
1800 W BROAD ST
ELIZABETHTOWN, NC, 28337