N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14337-36-5366
State Number
18249

EQUIPMENT INSPECTED

State Number: **18249**
Capacity: 2500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 09/13/1999
Complied: 09/13/1999

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 2

OWNER
TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215

OCCUPANT
TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/03/2014	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

None Found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: sue 336-524-9467 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
TWIN LAKES CENTER
100 WADE COBLE DR
BURLINGTON, NC, 27215