



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14339-17-3080**  
State Number  
**16051**

EQUIPMENT INSPECTED

State Number: <b>16051</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: US ELEVATOR	Speed: 125
Landings: 3	Installed: 03/20/1996	Rope Size:
Volts: 208	Complied: 03/20/1996	Entrances: 1
OWNER	OCCUPANT	
ARDEN PRESBYTERIAN CHURCH	ARDEN PRESBYTERIAN CHURCH	
2215 HENDERSONVILLE RD	2215 HENDERSONVILLE RD	
ARDEN, NC, 28704	ARDEN, NC, 28704	

INSPECTION INFORMATION

Inspection Date 12/05/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 01/04/2015

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dean 828-606-8668

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDEN PRESBYTERIAN CHURCH  
2215 HENDERSONVILLE RD  
ARDEN, NC, 28704