



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14356-54-0140
State Number
23092

EQUIPMENT INSPECTED

State Number: 23092	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 10/14/2005	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
NC DEPARTMENT OF CORRECTIONS	BERTIE CORRECTIONAL / RED-WING	
218 COOPER HILL RD	218 COOPER HILL RD	
WINDSOR, NC, 27983	WINDSOR, NC, 27983	

INSPECTION INFORMATION

Inspection Date 12/22/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

n/a No violations found

Elevator Name: RED

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CHARLES GURGANUS 252 794 8650

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NC DEPARTMENT OF CORRECTIONS
218 COOPER HILL RD
WINDSOR, NC, 27983