



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15005-48-0640
State Number
20696

EQUIPMENT INSPECTED

State Number: 20696	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 07/22/2002	Rope Size: 0
Volts: 208	Complied: 07/24/1992	Entrances: 1
OWNER	OCCUPANT	
COMMUNITY ASSOCIATION MGMT	CLEAR WATER PLACE	
CLEARWATER PLACE HOA	1620 GOLEY HEWETT RD.	
WILMINGTON, NC, 28403	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 01/05/2015	Type Inspection Routine	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK	10
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------	----

VIOLATIONS

- 8.1.1[c] Keys shall be kept on the premises in a location readily accessible to the personnel in the assigned group, but not where they are accessible to the general public.
- 2.15.2 Replace the cracked, worn, or missing car guides.

Items must be corrected by: 02/04/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MGMT
CLEARWATER PLACE HOA
WILMINGTON, NC, 28403