



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15026-17-3858
State Number
H1978

EQUIPMENT INSPECTED

State Number: H1978	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: TKE	Speed: 9
Landings: 2	Installed: 05/01/2008	Rope Size:
Volts: 115	Complied: 05/01/2008	Entrances: 2
OWNER	OCCUPANT	
10 BROOK STREET LLC	10 BROOK STREET	
10 BROOK ST STE 205	10 BROOK STREET	
ASHEVILLE, NC, 28803	ASHEVILLE, NC, 28803	

INSPECTION INFORMATION

Inspection Date 01/26/2015	Type Inspection Routine	Certificate Status Not Issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	----------------------------------	-------------------------	--------------------	------

VIOLATIONS

- a18.1 Repair or replace all damaged lift structure including doors ,door frames, facsia and any other weather related damages.
rec Lift should be out of the weather and repaired or replaced before going back into operation.
a18.1 Repair all doors to open and close properly.

Items must be corrected by: 02/05/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JoAnn

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

10 BROOK STREET LLC
10 BROOK ST STE 205
ASHEVILLE, NC, 28803