



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15026-36-021
State Number
24228

EQUIPMENT INSPECTED

State Number: 24228	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 10/31/2006	Rope Size: 0
Volts: 208	Complied: 10/31/2006	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	OAKS BUILDING (B)	
803 HAGGARD AVENUE	1002 ELON ACORN DRIVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/26/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

None Found

Elevator Name: BUILDING (B)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob 336.278.2000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244