N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15028-16-2551
State Number
6859

EQUIPMENT INSPECTED

State Number: **6859**
Capacity: 1300
Landings: 3
Volts: 220

Type of Unit: Passenger
Manuf: WESTBROOK
Installed: 06/15/1972
Complied: 07/25/1972

Floor to Floor: 1 to 2
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
BEAUFORT CO COURTHOUSE
123 W 3RD ST
WASHINGTON, NC, 27889

OCCUPANT
BEAUFORT CO COURT HOUSE
112 W SECOND ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
01/28/2015	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

8.6.4.7.1 Clean the elevator pit. Remove soiled oil pads from pit

Items must be corrected by: 02/27/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Annette / Facility Management

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BEAUFORT CO COURTHOUSE
123 W 3RD ST
WASHINGTON, NC, 27889