N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15043-7-2484
State Number
19883

EQUIPMENT INSPECTED

State Number: **19883**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 08/13/2001
Complied: 08/23/2001

Floor to Floor: 1 to 2
Speed: 95
Rope Size: 0
Entrances: 1

OWNER
ALEXANDER COUNTY SCHOOLS
700 LILEDOUN ROAD
TAYLORSVILLE, NC, 28681

OCCUPANT
ALEXANDER CENTRAL HIGH SCHOOL
241 SCHOOL AVENUE
TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/12/2015	Routine	Re-issued	7 - Hoffman	ALEXANDER

2

VIOLATIONS

8.11.3.2.1	PERFORM THE ANNUAL RELIEF VALVE TEST
8.6	CLEAN THE OIL DRY FROM THE PIT

Items must be corrected by: 03/14/2015

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: ALEXANDER CO. SCHOOLS 828-632-7063

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALEXANDER COUNTY SCHOOLS
700 LILEDOUN ROAD
TAYLORSVILLE, NC, 28681