



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15043-7-2958
State Number
H1660

EQUIPMENT INSPECTED

State Number: H1660	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 450	Manuf: ACCESS	Speed: 18
Landings: 2	Installed: 10/07/2005	Rope Size: 0
Volts: 115	Complied: 10/07/2005	Entrances: 2
OWNER	OCCUPANT	
ALEXANDER COUNTY SCHOOLS	ALEXANDER CENTRAL HIGH SCHOOL	
700 LILEDOWN ROAD	241 SCHOOL AVENUE	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/12/2015	Type Inspection Routine	Certificate Status Not Issued	Inspector 7 - Hoffman	County ALEXANDER
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------

2

VIOLATIONS

- 8.6 RESTORE LIFT TO PROPER WORKING ORDER
- 8.6 REPLACE MISSING BUTTON ON THE BOTTOM STATION

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ALEXANDER CO. SCHOOLS828-632-7063

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALEXANDER COUNTY SCHOOLS
700 LILEDOWN ROAD
TAYLORSVILLE, NC, 28681