



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15047-52-103**  
State Number  
**11208**

### EQUIPMENT INSPECTED

State Number: **11208**

Capacity: 4000

Landings: 2

Volts: 480

OWNER

JIM MOORE

P.O. BOX 3444

HICKORY, NC, 28603

Type of Unit: Freight

Manuf: ESCO

Installed: 01/09/1985

Complied: 01/09/1985

OCCUPANT

HANCOCK & MOORE FURNITURE

127 NORTH RINK DAM ROAD

TAYLORSVILLE, NC, 28603

Floor to Floor: 1 to 2

Speed: 50

Rope Size: 0

Entrances: 1

### INSPECTION INFORMATION

Inspection Date  
02/16/2015

Type Inspection  
Routine

Certificate Status  
Re-issued

Inspector  
52 - Sosebee

County  
ALEXANDER

2

### VIOLATIONS

2.14.7.1 Put the car lights in proper working order. Locate and label the elevator cab light feed.

Items must be corrected by: 03/18/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Hancock & Moore 828-495-8235

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JIM MOORE  
P.O. BOX 3444  
HICKORY, NC, 28603