



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15049-48-1553
State Number
26742

EQUIPMENT INSPECTED

State Number: **26742** Type of Unit: Passenger Floor to Floor: 1 to 2
Capacity: 2500 Manuf: OTIS Speed: 100
Landings: 2 Installed: 08/17/2009 Rope Size:
Volts: 208 Complied: 08/17/2009 Entrances: 1

OWNER

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462

OCCUPANT

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/18/2015	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/20/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Pastor Mooney

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462