



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15050-52-2172
State Number
5796

EQUIPMENT INSPECTED

State Number: 5796	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: REMCO	Speed: 30
Landings: 2	Installed: 05/23/1967	Rope Size: 0
Volts: 220	Complied: 08/24/1967	Entrances: 2

OWNER
ADAMS FUNERAL HOME LLC
P.O. BOX 937
TAYLORSVILLE, NC, 28681

OCCUPANT
ADAMS FUNERAL HOME
307 MAIN AVENUE DRIVE
TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date 02/19/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

8.11.3.2.1 Perform the semi- annual relief valve and system pressure test.

Items must be corrected by: 03/21/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Adams Funeral Home 828-632-2291

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ADAMS FUNERAL HOME LLC
P.O. BOX 937
TAYLORSVILLE, NC, 28681