N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15051-36-5965
State Number
28047

EQUIPMENT INSPECTED

State Number: **28047**
Capacity: 4500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 08/01/2011
Complied: 08/01/2011

Floor to Floor: 1 to 3
Speed: 125
Rope Size:
Entrances: 2

OWNER
EDG PROPERTIES LLC
PO BOX 2676
GREENSBORO, NC, 27402

OCCUPANT
ELON TOWN CENTER
130 N WILLIAMSON AVENUE
ELON, NC, 27244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/20/2015	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: 336) 538-9668 jmcdonald@gotdepot.come

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
EDG PROPERTIES LLC
PO BOX 2676
GREENSBORO, NC, 27402