



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15051-52-5151**  
State Number  
**10870**

#### EQUIPMENT INSPECTED

State Number: <b>10870</b>	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 2500	Manuf: OTIS	Speed: 150
Landings: 4	Installed: 10/25/1984	Rope Size: 0
Volts: 208	Complied: 10/25/1984	Entrances: 1

#### OWNER

HIDDENITE CENTER  
316 HIDDENITE CHURCH ROAD  
HIDDENITE, NC, 28636

#### OCCUPANT

LUCAS MANSION  
316 HIDDENITE CHURCH ROAD  
HIDDENITE, NC, 28636

#### INSPECTION INFORMATION

Inspection Date 02/20/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

#### VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
2.13.5.1	Put the car door reopening devices in proper working order.

Items must be corrected by: 03/22/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lucas Mansion 828-632-6966

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HIDDENITE CENTER  
316 HIDDENITE CHURCH ROAD  
HIDDENITE, NC, 28636