



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15052-48-5373
State Number
23969

EQUIPMENT INSPECTED

State Number: 23969	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 03/28/2006	Rope Size: 0
Volts: 230	Complied:	Entrances: 1
OWNER THE WOODLANDS @ CROW CREEK 10255 BEACH DR SW CALABASH, NC, 28467	OCCUPANT CROW CREEK CONDO 250 WOODLANDS WAY CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 02/20/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.3 Put the Phase II fire service feature in proper working order. [STOP SW. INOPERATIVE IN PHASE 2 OPERATION PANEL]
5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 03/23/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467