

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927

Report Number 15054-52-3410 State Number 21160

2

		919-707-7927		
		EQUIPMENT INSPECTED		
State Number: <b>21160</b>	ber: <b>21160</b> Type of Unit: Passer		nger Floor to Floor: 1 to 2	
Capacity: 4500 Manuf: THYSSEN		EN KRUPP	Speed: 125	
Landings: 2 Installed: 11/17/20		2003	Rope Size: 0	
Volts: 480 Complied: 11/17/2		003 Entrances: 1		
OWNER		OCCU	JPANT	
N.C. DEPTARTMENT OF CORRECTIONS		ALEXANDER CORRECTIONAL		
831 WEST MORGAN STREET		633 OLD LANDFILL ROAD		
RALEIGH, NC, 27603		TAYLORSVILLE, NC, 28681		
	IN	SPECTION INFORMATION		
Inspection Date Type Inspection 02/23/2015 Routine		Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER
		VIOLATIONS		
3.11.3.2.1 Perform the annua	l relief valve and system pressure test.			
Items must be corrected by: 03/25/2015		Elevator Name: # L		
lotify the Elevator Bureau in omplainace with current code	writing on Corrected Violations Formes.	when the following corrections	have been made in order to b	ring your equipment into
/iolations pointed out to: Alle	en 828-632-1331		Inspector	
	To make changes to the invoice m			
THIS IS NOT AN INVOICE An invoice will be mailed to:		N.C. DEPTARTMENT OF CORRECTIONS 831 WEST MORGAN STREET		

RALEIGH, NC, 27603