



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15055-48-3940**  
State Number  
**24566**

### EQUIPMENT INSPECTED

State Number: **24566**

Capacity: 2000

Landings: 3

Volts: 230

Type of Unit: Passenger

Manuf: THYSSEN KRUPP

Installed: 02/21/2007

Complied:

Floor to Floor: 1 to 3

Speed: 55

Rope Size: 0

Entrances: 1

#### OWNER

THE WOODLANDS @ CROW CREEK

10255 BEACH DR SW

CALABASH, NC, 28467

#### OCCUPANT

CROW CREEK - BLDG #13

395 S CROW CREEK DRIVE

CALABASH, NC, 28467

### INSPECTION INFORMATION

Inspection Date  
02/24/2015

Type Inspection  
Routine

Certificate Status  
Re-issued

Inspector  
48 - Martin

County  
BRUNSWICK

10

### VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/26/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK  
10255 BEACH DR SW  
CALABASH, NC, 28467