N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**15055-48-5522**
State Number
**24565**

## EQUIPMENT INSPECTED

| | | |
|---|---|---|
| State Number: **24565** | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2000 | Manuf: THYSSEN KRUPP | Speed: 55 |
| Landings: 3 | Installed: 03/07/2007 | Rope Size: 0 |
| Volts: 480 | Complied: | Entrances: 1 |

OWNER
THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467

OCCUPANT
CROW CREEK - BLDG #14
395 SOUTH CROW CREEK DR
CALABASH, NC, 28467

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County | |
|---|---|---|---|---|---|
| 02/24/2015 | Routine | Re-issued | 48 - Martin | BRUNSWICK | 10 |

## VIOLATIONS

| | |
|---|---|
| 2.27.1.1.2 | Put the in car emergency telephone in proper working order. |
| N/A | REMOVE TAPE FROM MR DR LOCK |

Items must be corrected by: 03/26/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467