



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15056-36-4543
State Number
24692

EQUIPMENT INSPECTED

State Number: 24692	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 01/14/2009	Rope Size:
Volts: 208	Complied: 01/14/2010	Entrances: 1
OWNER	OCCUPANT	
SLATTER MNG SERVICES INC	WINDEREMERE CONDOMINIUMS	
4125 G WALKER AVE	3010 WINSTON DR	
GREENSBORO, NC, 27407	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/25/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/07/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANDREA UNDER WOOD336-272-0641

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SLATTER MNG SERVICES INC
4125 G WALKER AVE
GREENSBORO, NC, 27407