



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.ncclabor.com/elevator.htm
919-707-7927

Report Number
15062-30-5079
State Number
H1607

EQUIPMENT INSPECTED

State Number: **H1607**

Capacity: 750

Landings: 3

Volts: 115

OWNER

AVERY COUNTY

P.O. BOX 640

NEWLAND, NC, 28657

Type of Unit: Hand Lift

Manuf: NATL W-O-V

Installed: 09/23/2005

Complied: 10/25/2005

OCCUPANT

AVERY COUNTY COURTHOUSE

200 MONTEZUMA STREET

NEWLAND, NC, 28657

Floor to Floor: 1 to 3

Speed: 9

Rope Size: 0

Entrances: 2

INSPECTION INFORMATION

Inspection Date
03/03/2015

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
4 - Henegar

County
AVERY

6

VIOLATIONS

8.6.4.15 Take steps to place the car emergency light and alarm bell in proper working order.

Items must be corrected by: 03/13/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County 828-733-8259

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY
P.O. BOX 640
NEWLAND, NC, 28657