



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15062-4-0251
State Number
13850

EQUIPMENT INSPECTED

State Number: **13850**

Capacity: 2100

Landings: 2

Volts: 208

OWNER

AVERY COUNTY

P.O. BOX 640

NEWLAND, NC, 28657

Type of Unit: Passenger

Manuf: THYSSEN KRUPP

Installed: 10/22/1990

Complied: 12/12/1990

OCCUPANT

AVERY COUNTY OFFICE BLDG.

175 LINVILLE STREET

NEWLAND, NC, 28657

Floor to Floor: 1 to 2

Speed: 100

Rope Size: 0

Entrances: 1

INSPECTION INFORMATION

Inspection Date
03/03/2015

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
4 - Henegar

County
AVERY

6

VIOLATIONS

8.11.1.6 Provide the appropriate test tag.

8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 03/13/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County 828-733-8259

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY
P.O. BOX 640
NEWLAND, NC, 28657