



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15068-16-4431
State Number
25187

EQUIPMENT INSPECTED

State Number: 25187	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: T KRUPP, HYD	Speed: 55
Landings: 3	Installed: 01/24/2008	Rope Size: 0
Volts: 208	Complied: 01/24/2008	Entrances: 1
OWNER	OCCUPANT	
BUOY TENDER STATION	BUOY TENDER	
PO BOX 2039	421 W MAIN STREET	
GREENVILLE, NC, 27836	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 03/09/2015	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------------	----------------------------------	-------------------------	--------------------

7

VIOLATIONS

Elevator Not Working

Elevator Name: elevator # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David Elks

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BUOY TENDER STATION
PO BOX 2039
GREENVILLE, NC, 27836