



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15068-36-3956**  
State Number  
**29716**

EQUIPMENT INSPECTED

State Number: <b>29716</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1400	Manuf: CUSTOM ELEV INC	Speed: 30
Landings: 2	Installed: 03/09/2015	Rope Size:
Volts: 220	Complied: 03/09/2015	Entrances: 1

OWNER

BURLINGTON CHRISTIAN CHURCH  
301 TRAIL FOUR  
BURLINGTON, NC, 27215

OCCUPANT

BURLINGTON CHRISTIAN CHURCH  
301 TRAIL FOUR  
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 03/09/2015	Type Inspection New	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

place fire alarm in proper worker order.

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KEVIN DINWIDDIE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BURLINGTON CHRISTIAN CHURCH  
301 TRAIL FOUR  
BURLINGTON, NC, 27215