



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15072-4-5870**  
State Number  
**13317**

EQUIPMENT INSPECTED

State Number: <b>13317</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SOUTHERN	Speed: 100
Landings: 2	Installed: 08/23/1989	Rope Size: 0
Volts: 208	Complied: 08/23/1989	Entrances: 1
OWNER	OCCUPANT	
GRANDFATHER COUNTRY CLUB	GRANDFATHER COUNTRY CLUB	
2120 HWY.105 NORTH	1225 HWY.105 NORTH	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 03/13/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY	6
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------	---

VIOLATIONS

- 8.11.1.6 Provide the missing metal tag in the machine room with all pertinent information of the test performed. (Category 3 & 5 electric elevators; category 1, 3, 5 hydraulic elevators)
- 8.6.4.7.4 Take steps to eliminate the accumulation of water on the pit floor and remove same.
- 2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 04/12/2015

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Grandfather Country Club 828-896-4531

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRANDFATHER COUNTRY CLUB  
2120 HWY.105 NORTH  
LINVILLE, NC, 28646