



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15076-17-2213**  
State Number  
**26812**

EQUIPMENT INSPECTED

State Number: <b>26812</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 06/09/2009	Rope Size:
Volts: 208	Complied: 06/09/2009	Entrances: 1
OWNER	OCCUPANT	
ARDEN SEVENTH DAY ADVENTIST CHURCH	ARDEN SEVENTH DAY ADVENTIST CHURCH	
35 AIRPORT ROAD	35 AIRPORT ROAD	
ARDEN, NC, 28704	ARDEN, NC, 28704	

INSPECTION INFORMATION

Inspection Date 03/17/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.10.1 Provide an updated monthly fire service log indicating proper Phase 1 and 2 operation and make available upon request the authority having jurisdiction.

Items must be corrected by: 04/16/2015

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDEN SEVENTH DAY ADVENTIST CHURCH  
35 AIRPORT ROAD  
ARDEN, NC, 28704