



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15082-48-3923
State Number
24237

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 24237 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2500 | Manuf: OTIS | Speed: 125 |
| Landings: 3 | Installed: 01/30/2007 | Rope Size: 0 |
| Volts: 208 | Complied: 01/30/2007 | Entrances: 1 |

OWNER
CHAD MORRIS
371 NORTH BILHEN STREET
TROY, NC, 27371

OCCUPANT
YAUPON DUNES
700 OCEAN DRIVE
OAK ISLAND, NC, 28461

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 03/23/2015 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

2.27.3.3 Put the Phase II fire service feature in proper working order. [CAR BUTTONS NOT LATCHING TO RUN ON PHASE 2].

Items must be corrected by: 04/22/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CHAD MORRIS
371 NORTH BILHEN STREET
TROY, NC, 27371