



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15084-48-1079**  
State Number  
**7118**

#### EQUIPMENT INSPECTED

State Number: <b>7118</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 10/24/1973	Rope Size: 1/2
Volts: 480	Complied: 12/10/1973	Entrances: 1
OWNER	OCCUPANT	
DUKE ENERGY	DUKE ENERGY - CONTROL ROOM	
8470 RIVER ROAD SE	8470 RIVER ROAD SE	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

#### INSPECTION INFORMATION

Inspection Date 03/25/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

2.14.1.5.1      Secure the car top emergency exit.

Items must be corrected by: 04/24/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JWANTANA FRINK

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DUKE ENERGY  
8470 RIVER ROAD SE  
SOUTHPORT, NC, 28461