



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15084-48-5462
State Number
14768

EQUIPMENT INSPECTED

State Number: 14768	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 08/10/1992	Rope Size:
Volts: 480	Complied: 08/10/1992	Entrances: 1
OWNER	OCCUPANT	
DUKE ENERGY	DUKE ENERGY - OFFICE BLDG.	
8470 RIVER ROAD SE	8470 RIVER ROAD SE	
SOUTH PORT, NC, 28461	SOUTH PORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 03/25/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 04/24/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JWANTANA FRINK

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DUKE ENERGY
8470 RIVER ROAD SE
SOUTH PORT, NC, 28461