



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15090-4-033
State Number
11260

EQUIPMENT INSPECTED

State Number: 11260	Type of Unit: Freight	Floor to Floor: 2 to 3
Capacity: 1500	Manuf: ACE	Speed: 100
Landings: 2	Installed: 07/15/1986	Rope Size: 0
Volts: 208	Complied: 07/18/1986	Entrances: 1

OWNER

N.C. WILDERNESS LIMITED
P.O. BOX 704
LINVILLE, NC, 28646

OCCUPANT

LINVILLE RIDGE CLUBHOUSE
7000 RIDGE ROAD
LINVILLE, NC, 28646

INSPECTION INFORMATION

Inspection Date 03/31/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.11.1.6 Provide a metal with test date, the requirement number requiring the test, and the name of the person or firm performing the test inside the machine room for all Categories 3, 5 tests for electric elevators and 1,3, 5 tests for hydraulic elevators

Items must be corrected by: 04/30/2015

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Linville Ridge 828-898-5151

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. WILDERNESS LIMITED
P.O. BOX 704
LINVILLE, NC, 28646