



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15090-4-1513**  
State Number  
**16223**

EQUIPMENT INSPECTED

State Number: <b>16223</b>	Type of Unit: Passenger	Floor to Floor: LL to UL
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 3	Installed: 11/14/1996	Rope Size: 0
Volts: 460	Complied: 11/25/1996	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY SCHOOLS	FREEDOM TRAIL ELEMENTARY	
775 CRANBERRY STREET	6230 HWY19 EAST	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 03/31/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.6.1.6.3[e]	Properly secure car station panel
2.27.3.3	Put the Phase II fire service feature in proper working order.
8.6.5.5.2	Repair the drain line to bucket in the pit.
8.6.4.7.1	Clean the elevator pit.
5.1.21.1	Place the in car emergency light and alarm bell in working order.

Items must be corrected by: 04/10/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County 828-733-6006

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY SCHOOLS  
775 CRANBERRY STREET  
NEWLAND, NC, 28657