



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15090-4-2376
State Number
26961

EQUIPMENT INSPECTED

State Number: 26961	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 150
Landings: 3	Installed: 04/01/2010	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
GRANDFATHER MOUNTAIN	GRANDFATHER MOUNTAIN TOP SHOP	
P.O. BOX 129	2050 BLOWING ROCK HWY	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 03/31/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.6.4.7.4	Remove the oil from the pit floor.
8.6.5.5.2	Empty the drain bucket in the pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order. 2ND NOTICE
8.6.1.5.2	Provide periodic test code data plate size, type and lettering
8.11.3.2.1	Provide the annual relief valve and system pressure test.

Items must be corrected by: 04/10/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Grandfather Mtn. 828-733-2800

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRANDFATHER MOUNTAIN
P.O. BOX 129
LINVILLE, NC, 28646