N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15090-4-2426
State Number
28677

EQUIPMENT INSPECTED

State Number: **28677**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 01/02/2013	Rope Size:
Volts: 208	Complied:	Entrances: 1

OWNER
LINVILLE COVE LIMITED PARTNERS
507 LINVILLE STREET
NEWLAND, NC, 28657

OCCUPANT
LINVILLE COVE APARTMENTS
507 LINVILLE STREET
NEWLAND, NC, 28657

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/31/2015	Not Inspected	Not Issued	4 - Henegar	AVERY

6

VIOLATIONS

Not Inspected

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Linville Cove Apts. 828-387-0878 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LINVILLE COVE LIMITED PARTNERS
507 LINVILLE STREET
NEWLAND, NC, 28657