



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15100-48-3815
State Number
H1321

EQUIPMENT INSPECTED

State Number: H1321	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: THYSSEN KRUPP	Speed: 15
Landings: 2	Installed: 10/04/2002	Rope Size: 0
Volts: 115	Complied: 10/04/2002	Entrances: 2
OWNER WINDSOR UNITED METHODIST CHURCH % MARTHA CULBREATH FAYETTEVILLE, NC, 28312		OCCUPANT WINDSOR METHODIST CHURCH 12880 NC HWY 242 AMMON, NC, 28441

INSPECTION INFORMATION

Inspection Date 04/10/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

8.6.4.13.1[k]	Properly maintain door closers, where required. [CAR GATE]
N/A	REPAIR TOP RUN SWITCH. [BROKEN] [2ND. YR.]
N/A	CLEAN OUTSIDE UNIT. [LEAVES] [2ND YR.]

Items must be corrected by: 05/10/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WINDSOR UNITED METHODIST CHURCH
% MARTHA CULBREATH
FAYETTEVILLE, NC, 28312