



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15103-48-1922**  
State Number  
**26232**

#### EQUIPMENT INSPECTED

State Number: <b>26232</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 135
Landings: 2	Installed: 01/28/2009	Rope Size:
Volts: 200	Complied: 01/28/2009	Entrances: 1
OWNER	OCCUPANT	
OAK ISLAND TOWN HALL	SOUTH HARBOR VILLAGE FIRE DEPARTMENT	
4601 E. OAK ISLAND DR.	4151 VANESSA DRIVE	
OAK ISLAND, NC, 28465	OAK ISLAND, NC, 28465	

#### INSPECTION INFORMATION

Inspection Date 04/13/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

#### VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 05/13/2015

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANDY DICK

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OAK ISLAND TOWN HALL  
4601 E. OAK ISLAND DR.  
OAK ISLAND, NC, 28465