



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15103-48-3977**  
State Number  
**24779**

EQUIPMENT INSPECTED

State Number: <b>24779</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 05/17/2007	Rope Size: 0
Volts: 208	Complied: 05/17/2007	Entrances: 1
OWNER	OCCUPANT	
SOUTH HARBOUR STATION	SOUTH HARBOR	
305 NORTH HOWE STREET	4134 VANESSA DRIVE	
SOUTHPORT,NC, NC, 28461	OAK ISLAND, NC, 28429	

INSPECTION INFORMATION

Inspection Date 04/13/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.27.3.3 Put the Phase II fire service feature in proper working order. [CALL CANCEL BUTTON INOPERATIVE] [SAME AS LAST YR.].
- 5.1.21.1 Put the in car alarm bell in working order.
- 8.6.4.13.1 All landing and car-door or gate mechanical and electrical components shall be maintained to ensure safe and proper operation. [NOISY DOOR OPERATOR]

Items must be corrected by: 05/13/2015

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTH HARBOUR STATION  
305 NORTH HOWE STREET  
SOUTHPORT,NC, NC, 28461