



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15105-48-2991
State Number
26754

EQUIPMENT INSPECTED

State Number: 26754	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: TKE	Speed: 80
Landings: 2	Installed: 07/10/2009	Rope Size:
Volts: 480	Complied: 07/10/2009	Entrances: 1
OWNER	OCCUPANT	
PENDER BOARD OF EDUCATION	NEW HANOVER REG. MEDICAL CENTER	
925 PENDERLEA HWY.	1333 S DICKINSON STREET	
BURGAW, NC,	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 04/15/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.5.5.2 Empty the drain bucket in the pit.

Items must be corrected by: 05/15/2015

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: L. KERRY

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PENDER BOARD OF EDUCATION
925 PENDERLEA HWY.
BURGAW, NC,