



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15118-48-3455
State Number
20567

EQUIPMENT INSPECTED

State Number: 20567	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 12/03/2001	Rope Size:
Volts: 208	Complied: 12/03/2001	Entrances: 1
OWNER	OCCUPANT	
TRINITY UNITED METHODIST CHURCH	TRINITY UNITED METHODIST CHURCH	
209 E. NASH ST.	300 HOWE ST	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 04/28/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 05/28/2015

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RONNIE PICKLER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TRINITY UNITED METHODIST CHURCH
209 E. NASH ST.
SOUTHPORT, NC, 28461