



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15119-17-0835
State Number
24208

EQUIPMENT INSPECTED

State Number: 24208	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: AEC	Speed: 100
Landings: 2	Installed: 08/31/2006	Rope Size: 0
Volts: 575	Complied: 08/31/2006	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COL	HAYNES SMALL BUSINESS CENTER	
1459 SAND HILL ROAD	1459 SAND HILL ROAD	
CANDLER, NC, 28715	CANDLER, NC, 28715	

INSPECTION INFORMATION

Inspection Date 04/29/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note no violations

Items must be corrected by: 04/29/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COL
1459 SAND HILL ROAD
CANDLER, NC, 28715