N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15120-17-1313
State Number
6962

EQUIPMENT INSPECTED

State Number: **6962**	Type of Unit: Freight	Floor to Floor: G to 4
Capacity: 11000	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 08/23/1971	Rope Size: 5/8
Volts: 550	Complied: 09/07/1971	Entrances: 1

OWNER	OCCUPANT
ASHEVILLE BUNCOMBE TECH COLL	ASHEVILLE BUNCOMBE TECH COMM COLLEGE
340 VICTORIA RD	1459 SANDHILL RD.
ASHEVILLE, NC, 28801	CANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/30/2015	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.6.4	Repair car safety edge.
8.11	Tag all governors and car tops for 5 year full load tests.
ncbc	Provide a machine room sign

Items must be corrected by: 05/30/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Eddie

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801