N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15120-17-1767
State Number
4309

EQUIPMENT INSPECTED

State Number: **4309**	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 3000	Manuf: OTIS	Speed: 300
Landings: 4	Installed: 02/19/1960	Rope Size: 5/8
Volts: 240	Complied: 02/19/1960	Entrances: 1

OWNER	OCCUPANT
ASHEVILLE BUNCOMBE TECH COLL	ASHEVILLE BUNCOMBE TECH COMM COLLEGE
340 VICTORIA RD	1459 SANDHILL RD.
ASHEVILLE, NC, 28801	CANDLER, NC, 28715

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/30/2015	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.6.4	Repair 1st floor hall station.
ncbc	Provide a machine room sign.
rec	Emergency number car, inside car, machine room.

Items must be corrected by: 05/30/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Eddie

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801