



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15120-17-2687
State Number
6775

EQUIPMENT INSPECTED

| | | |
|---------------------------|-------------------------|------------------------|
| State Number: 6775 | Type of Unit: Passenger | Floor to Floor: G to 7 |
| Capacity: 2500 | Manuf: WESTINGHOUSE | Speed: 350 |
| Landings: 8 | Installed: 11/24/1970 | Rope Size: 1/2 |
| Volts: 550 | Complied: 02/02/1971 | Entrances: 1 |

OWNER

ASHEVILLE BUNCOMBE TECH COLL
340 VICOTRIA RD
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE BUNCOMBE COLL
1459 SANDHILL RD.
CANDLER, NC, 28715

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|
| Inspection Date 04/30/2015 | Type Inspection Routine | Certificate Status Re-issued | Inspector 17 - White | County BUNCOMBE | 11 A |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|

VIOLATIONS

| | |
|-----------|---|
| 8.6.4.1.1 | Clean the pit |
| 8.6.4 | Relay M19E is blocked. |
| 2.,29 | Emergency number cars, interior, car top, machine room. |
| 8.6.4 | Check proper sheave depth on main drive sheave. |

Items must be corrected by: 05/30/2015

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COLL
340 VICOTRIA RD
ASHEVILLE, NC, 28801