



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15132-59-0259
State Number
10294

EQUIPMENT INSPECTED

State Number: 10294	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: GENERAL	Speed: 100
Landings: 4	Installed: 07/09/1982	Rope Size:
Volts: 208	Complied: 07/09/1982	Entrances: 1

OWNER

72 PATTON ASSOCIATES
72 PATTON AVENUE
ASHEVILLE, NC, 28801

OCCUPANT

72 PATTON ASSOCIATES
72 PATTON AVENUE
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 05/12/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 59 - Cannon	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

none

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: marjorie/receptionist

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

72 PATTON ASSOCIATES
72 PATTON AVENUE
ASHEVILLE, NC, 28801