



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15138-16-1241**  
State Number  
**29292**

EQUIPMENT INSPECTED

State Number: <b>29292</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 04/15/2014	Rope Size:
Volts: 208	Complied: 04/15/2014	Entrances: 1
OWNER	OCCUPANT	
WASHEYE LLC	WASHINGTON EYE CENTER	
4005 RIVER PARK DRIVE	1730 CAROLINA AVENUE	
SUFFOLK, VA, 23435	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 05/18/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.6.1.2.1	Provide a written maintenance program.
2.14.7.1.4	Put the car top light in working order.
8.6.4.7.4	Remove the water from the pit floor.
8.11.3.2.1	Provide the annual relief valve and system pressure test.

Items must be corrected by: 06/17/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Front Office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WASHEYE LLC  
4005 RIVER PARK DRIVE  
SUFFOLK, VA, 23435