



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15149-59-2888**  
State Number  
**11371**

EQUIPMENT INSPECTED

State Number: <b>11371</b>	Type of Unit: Passenger	Floor to Floor: B to 4
Capacity: 2500	Manuf: ASHEVILLE	Speed: 135
Landings: 5	Installed: 12/22/1986	Rope Size:
Volts: 208	Complied: 01/05/2007	Entrances: 1

OWNER

11 NORTH MARKET ST. BLDG.  
11 N. MARKET STREET  
ASHEVILLE, NC, 28801

OCCUPANT

11 NORTH MARKET ST. BLDG.  
11 N. MARKET STREET  
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 05/29/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 59 - Cannon	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

2.14.7.1.4 Put the car top light in working order.  
2.27 Fire signs needed on every landing.  
note Ceiling tiles should have a flame spread rating of 0 to 75 and a smoke development of 0 to 450 Do the tiles meet these requirements?

Items must be corrected by: 06/28/2015

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jimmy/maintenance

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:  
11 NORTH MARKET ST. BLDG.  
11 N. MARKET STREET  
ASHEVILLE, NC, 28801