N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15154-17-4434
State Number
18143

EQUIPMENT INSPECTED

State Number: **18143**
Capacity: 2500
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 11/23/1998
Complied: 11/23/1998

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
ARBOR TERRACE
3199 SWEETEN CREEK ROAD
ASHEVILLE, NC, 28803

OCCUPANT
ARBOR TERRACE
3199 SWEETEN CREEK ROAD
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
06/03/2015	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.11 Test pit over speed valve due to no tag on valve.

Items must be corrected by: 07/03/2015 Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: George 828-681-5533 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ARBOR TERRACE
3199 SWEETEN CREEK ROAD
ASHEVILLE, NC, 28803