



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15155-60-4689**  
State Number  
**25868**

EQUIPMENT INSPECTED

State Number: <b>25868</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 03/27/2008	Rope Size: 0
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
YMCA OF AVERY COUNTY	YMCA OF AVERY COUNTY	
436 HOSPITAL DRIVE	436 HOSPITAL DRIVE	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 06/04/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 60 - Kircher	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.11.1.6 Provide the appropriate test tag. (Needs Category 5 Periodic test tag)

Items must be corrected by: 07/04/2015

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dennis 828-737-7588

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

YMCA OF AVERY COUNTY  
436 HOSPITAL DRIVE  
LINVILLE, NC, 28646