



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15162-48-2673
State Number
25981

EQUIPMENT INSPECTED

State Number: 25981	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 130
Landings: 2	Installed: 01/27/2009	Rope Size:
Volts: 200	Complied: 01/27/2009	Entrances: 1

OWNER

DIXIE GENERAL CONTRACTORS
1236 N TEACHY ROAD
WALLACE, NC, 28466

OCCUPANT

HOLDEN BEACH NEW TOWN HALL
110 ROTHSCHILD STREET
HOLDEN BEACH, NC, 28462

INSPECTION INFORMATION

Inspection Date 06/11/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1 Put the Phase I fire service feature in proper working order. [NO FIRE HAT LIGHT AT KEY SWITCH] [SAME AS LAST YR.]

Items must be corrected by: 07/11/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIXIE GENERAL CONTRACTORS
1236 N TEACHY ROAD
WALLACE, NC, 28466